

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by B. M. Rawat(Name of Officers with designation) from A. E.(Name of Department/ Office) inspected the U. J. S. Kotdwara

(Name & Address of the school) on 10/10/25 (date of inspection) and found that the
S. G. R. R. Public School (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 10/2/25 to 6 month

Signature with Seal:

Name

Designation

Name & Address of the Office: सहायक अभियन्ता
पदामपुर देवी रोड, कोटद्वार

To

S. G. R. R. Public School
Padampur Devi Road, Kotdwara

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Kotdwar

Ph (O): 01382 – 222219, E-mail: ujseekotdwar@gmail.com

Test Report ID: 01/UJS/SLWQTML/2024-25

Dated: 10/02/2025

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	S.G.R.R Public School Padampur, Devi Road, Kotdwar (Garhwal)		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from S.G.R.R Public School Kotdwar
Reference Sample Identification: & Payment Receipt No.:	SDWQTML/UJSK/-01 O-RG/3432, RG 17090656 (01/02/2025)		Date of Start of Analysis: 05/02/2025
Date and Time of Sample Received: 05/02/25 & 10:40 AM	Sample Collected by:		Manish Rauthan

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.85	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/L	404	500	2000	IS 3025 Pt-16-2017.
3.	Turbidity, NTU	0.13	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/L	318	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO ₃), mg/L	246	200	600	IS 3025 Pt-21: 2002
6.	Chloride, mg/l	15.99	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	86.4	75	200	IS 3025 Pt-40 : 2019
8.	Magnesium (as Mg), mg/L	7.29	30	100	APHA 23rd Ed.-3500-Mg B: 2017
9.	Colour, Hazen	Less than 05	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012
	(B.) Biological Parameters				
12.	E-Coli	Absent	Absent	Absent	MPN
13.	Total Coliform	Absent	Absent	Absent	MPN

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Kuldeep Singh
(Chemist)

J.E.

सहायक अभियन्ता (नगर)
उत्तराखण्ड जल संस्थान कोटद्वार
पौड़ी गढ़वाल

-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.